



## OFFICE OF INSURANCE AND SAFETY FIRE COMMISSIONER

**RALPH T. HUDGENS**  
COMMISSIONER OF INSURANCE  
SAFETY FIRE COMMISSIONER  
INDUSTRIAL LOAN COMMISSIONER  
COMPTROLLER GENERAL

SEVENTH FLOOR, WEST TOWER  
FLOYD BUILDING  
2 MARTIN LUTHER KING, JR. DRIVE  
ATLANTA, GA 30334  
(404) 656-2056  
[www.oci.ga.gov](http://www.oci.ga.gov)

April 3<sup>rd</sup>, 2015  
Alliance Truck and Tank Sales, LLC  
John Yovetich  
410 Expressway, Suite A  
Missoula, MT 59808


Mr. Yovetich,

After a review of your proposed use of 18,000 to 30,000 gallon "skid" tank systems for use as a means of temporary storage of LP-Gas, it has been determined that your proposal meets applicable provisions of NFPA 58. The "skid" tank systems will be accepted for use within the State of Georgia provided the following requirements are met:

- 1) Plans for all proposed systems involving storage of over 2,000 gallons shall be submitted for approval prior to installation as required by and in accordance with Georgia Rules and Regulations 120-3-16.
- 2) The installation shall be in compliance with NFPA 58 (adopted edition at time of plan approval) and 120-3-16.
- 3) The systems shall be placed on a base of concrete, asphalt, or earth. Where the system is to be placed on earth, compaction testing shall be conducted and the results provided to the State Fire Marshal along with the plans. Additionally, where the systems are placed on earth, a compacted gravel base shall be used.
- 4) In accordance with NFPA 58, temporary systems of this type shall be used for a maximum of 12 months. This time frame will be from the date of plan approval. Upon conclusion of the temporary approval the systems shall be removed.
- 5) Installations at existing licensed bulk plants will be allowed to operate under the current license. Installations at new locations must be licensed as new facilities in accordance with 120-3-16.

This letter is not intended to constitute an "approval" of this system by the Georgia State Fire Marshal's Office in any way; it is only a notification accepting the system for use within the State. Please feel free to contact me at 404-357-4340 if I can be of any further assistance.

Thank You,

  
Jason Pritchett  
Fire Safety Compliance Officer